



SERIES 69S – GUIDE SPECIFICATION

BELT DRIVE UPBLAST ROOF VENTILATOR, STEEL

The Belt Drive Upblast Roof Ventilator, Swingout Type, Steel shall be manufactured by Hartzell Air Movement, Series 69S. Standard sizes are 12" through 60". The ventilators shall be packaged, pre-assembled units, capable of swinging the motor, drive components and the propeller clear of the roof opening.

The duct fan propeller shall be an airfoil design, cast of 319 aluminum in compliance with Federal Specification QQ-A-601E and ASTM B26. Propellers shall be retained on the fan shaft utilizing a split taper lock bushing. The motor shall be mounted on an adjustable motor base that is out of the airstream. Motor base shall be slotted to permit changing motor sizes if ventilation requirements change.

Fan shafts shall be ground and polished carbon steel. Bearings shall be located in a drive compartment on the negative pressure side of the propeller, drawing outside ambient air in and over the belts and bearings. Bearings shall be heavy duty, self-aligning, ball or roller type; depending on fan size, motor horsepower, and performance. Bearings shall have extended lube tubes and be relubricable for continuous service and have a minimum L10 life of 50,000 hours. Variable pitch drive sheaves shall be standard on fans up through and including 10 HP.

Fan housing shall be minimum 12 gauge commercial quality, carbon steel continuously welded in compliance with AWS D1.1 standard. The stack cap shall be constructed of minimum 20 gauge painted galvanized coated steel in sizes 12" through 60"; painted hot rolled 10 gauge steel. Butterfly dampers open when the unit is on; close weather-tight when the unit is off. Curb mounting panel shall have a venturi orifice on sizes 12" through 60"; a flat curb panel on larger sizes.

The fan assembly shall be dynamically balanced at the Hartzell factory prior to shipping. Fans shall be balanced to the American National Standards Institute, Std. S2.19-1989 "Balance Quality of Rotating Rigid Bodies", and Grade G6.3. Fans shall be manufactured in accordance with Hartzell's standard quality assurance procedures. Fan performance shall be based on tests conducted in Hartzell's AMCA accredited test laboratory in accordance with the latest revision of AMCA Standard 210 for air performance and AMCA Standard 300 for sound. Fans shall be licensed to bear the AMCA Certified Air and Sound Performance Rating Seal.

ACCESSORIES:

- Special Construction - Available in stainless steel, aluminum.
- Protective Coatings - Hot dipped galvanized, Nupon epoxy, inorganic zinc, and catalyzed coal tar epoxy are available upon request.
- Motors - OEDP standard. TEFC and other special motors can be furnished upon request.
- Inlet/Outlet Guard - Prevents access to rotating propeller.
- Shaft Seal and Slinger - Neoprene seal and slinger prevent contaminants from entering bearing compartment.
- Lifting Lugs - Provides means to lift and handle fans.
- Combination Motor Cover and Belt Guard - Covers are vented.